

# Analysts, Inc.

STATUS WAS

**Monitor** ON 17-Nov-08

ISO 9001 REGISTERED  
2450 Hassell Road  
Hoffman Estates IL 60195  
(800) 222-0071

UNIT I.D.: A-2096  
COMPONENT: COOLANT  
COMP. REF. NO.: 9252030  
P.O./REF NO.:

WORKSITE	UNIT MANUFACTURER ONAN DFHA	COOLANT TYPE DNA
COMPONENT TYPE COOLANT	COMPONENT MANUFACTURER AND MODEL ONAN DFHA-4963829	COMPONENT SERIAL NUMBER

MAINTENANCE RECOMMENDATIONS FOR LAB NO. 6317 Reported On: 28-NOV-08




ANALYSIS REFLECTS CONDITIONS / VALUES NOTED FOR MONITORING PURPOSES ONLY. Other test results are satisfactory. RESAMPLE at the next scheduled interval.

### SPECTROCHEMICAL ANALYSIS IN PARTS PER MILLION BY WEIGHT

EVAL ID: 1302	SPECTROCHEMICAL ANALYSIS IN PARTS PER MILLION BY WEIGHT																	SAMPLE DRAWN				
LAB NO.	Iron	Chromium	Nickel	Aluminum	Lead	Copper	Tin	Silver	Titanium	Silicon	Boron	Sodium	Potassium	Molybdenum	Phosphorus	Zinc	Calcium	Barium	Magnesium	Antimony	Vanadium	SAMPLE DRAWN
6317	4	<1		4	<1	49		<.1	46		195	>999	>999	82	48	11	<10	<10	<1			17-Nov-08

SAMPLE INFORMATION							PHYSICAL TEST RESULTS					
LAB NO.	Mi/HR Unit	Mi/HR Coolant	Make-Up Added	FLTR CHG	OIL CHG	pH	NITR. ppm	FREEZE PT. °F	R.A. /ml.	A/F %	VISUAL COLOR	VISUAL-APPEAR.
6317			n	n		8.0	800	-46	4.2	54	TAN	CLEAR



UNDERLINED FIGURES INDICATE SIGNIFICANT VALUES. MAINTENANCE THAT MAY BE REQUIRED IS INDICATED ABOVE UNDER MAINTENANCE RECOMMENDATIONS AND SHOULD BE PERFORMED BY A QUALIFIED MECHANIC. PLEASE ADVISE US OF ANY MAINTENANCE PERFORMED ON THIS UNIT.

ACCURACY OF RECOMMENDATIONS IS DEPENDENT ON REPRESENTATIVE SAMPLE AND COMPLETE, CORRECT DATA ON BOTH THE UNIT AND SAMPLE. THIS REPORT IS NOT AN ENDORSEMENT OR RECOMMENDATION OF ANY PRODUCT OR SYSTEM. ORIGINAL REPORTS MAINTAINED IN ANALYSTS, INC. DATA FILES.

FOR LEGEND AND EXPLANATION OF PHYSICAL PROPERTIES TESTS PLEASE SEE: <http://www.analystsinc.com/legend.jsp>

NOTE: 'L' after SAMPLE DRAWN indicates date was NOT provided, displayed date is process date.

N/R = TEST NOT PERFORMED

COPYRIGHT © 1990 ANALYSTS, INC.

Form NO. 6002-E 11/98